

4. Classification and direct field of application

4.1. Reference

This classification has been carried out in accordance with clause 10.8.2 in EN 13501-1:2002.

4.2. Classification

The Rockfon ceiling membrane **Rockfon Soundstop** 2 x 30 mm, in relation to its reaction to fire behaviour is classified:

A1

The format of the reaction to fire classification for construction products except flooring is:

Fire behavior
A1

Reaction to fire classification: A1

4.3. Field of application

This classification is valid for all end use conditions:

This classification is also valid for the following product parameters:

Density range, mineral wool: 110 kg/m³ +/- 10%

Thickness range: 2 x 30 mm

The manufacturer has made a declaration, which is held on file. This confirms that the product's design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.


The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is claimed to be relevant to the samples tested and that will provide for their traceability."

Issued by:



Kurt Ejlersen
Senior Fire Technician

Approved by:



Martin Bagge
Manager, Testing & Quality