

# F TECH 003 CERTIFICAT OF CONFORMITY TILES MEDICARE PLUS N° 10 12 160 – ROCKFON MediCare PLUS/ 1 Ver.0



**Given by** : CERA-LABO  
ZI de la Montagne de l'Aspre  
30150 ROQUEMAURE - France

**to** : **ROCKFON**

**Report** : **10 12 160 – ROCKFON MediCare PLUS/ 1 Ver.0** written the **17<sup>th</sup> march 2011** and **11 09 087 ROCKFON MediCare Air/ 1 Ver.0** written the **28<sup>th</sup> September 2011**

## Conclusions :

The tiles MEDICARE PLUS can be used in room of area 4 according to the norm NFS 90-351 : 2003.

- The particular class of the face in normal conditions is ISO class 5 according to the norm ISO 14644-1 : 1999.
- The particular class of the back in normal conditions is ISO class 5 according to the norm ISO 14644-1 : 1999.
- The recovery time is below to  $CP_{(0,5),10}$  according to the norm NF S 90-351 : 2003.
- The microbiological class according to the norm NF S 90-351 : 2003 is :

<b>B1</b>
Methicilin resistant Staphylococcus aureus (MRSA)
Aspergillus niger
Candida albicans

- The painted face doesn't allow the growth of microorganism S.aureus (CIP 103.514).

## GENERAL CONCLUSIONS OF TILES MEDICARE PLUS

### Classification of tiles

The tiles MEDICARE PLUS can be used in room of area 4 according to the norm NFS 90-351 : 2003.

Tests		Norms	Acceptance criteria	Real values	Conformity
Particular class normal conditions face		ISO 14644-1	ISO class 5	ISO class 5	Conform
Particular class normal conditions back		ISO 14644-1	ISO class 5	ISO class 5	Conform
Recovery time		NF S 90-351	CP <sub>(0,5)</sub> 10	2.4 minutes	Conform
Microbiology air test	<i>Methicilin resistant Staphylococcus aureus (MRSA)</i>	NF S 90-351	B10	B1	Conform
	<i>Aspergillus niger</i>	NF S 90-351	B10	B1	Conform
	<i>Candida albicans</i>	NF S 90-351	B10	B1	Conform

### Remarks

- This controls shows that the tiles MEDICARE PLUS could be used in area 4 according to the norm NF S 90-351 : 2003.
- The microbiological tests as been made under Microbiological Safety Cabinet
- The completed results are in the report :  
n° 10 12 160 – ROCKFON MediCare PLUS/ 1 Ver.0 written the 17<sup>th</sup> march 2011 and 11 09 087 ROCKFON MediCare Air/1 Ver.0 written the 28<sup>th</sup> September 2011

  
**The Director**