

F TECH 003 CERTIFICAT OF CONFORMITY TILES MEDICARE STANDARD N° 10 12 160 – ROCKFON MediCare Standard / 1 Ver.0



Given by : CERA-LABO
ZI de la Montagne de l'Aspre
30150 ROQUEMAURE - France

to : **ROCKFON**

Report : **10 12 160 – ROCKFON MediCare Standard / 1 Ver.0** written the **20th January 2011** and **11 09 087 ROCKFON MediCare Air/1 Ver.0** written the **28th September 2011**

Conclusions :

The tiles MEDICARE STANDARD can be used in room of area 4 according to the norm NFS 90-351 : 2003.

- The particular class of the face in normal conditions is ISO class 5 according to the norm ISO 14644-1 : 1999.
- The particular class of the back in normal conditions is ISO class 5 according to the norm ISO 14644-1 : 1999.
- The recovery time is below to CP_(0,5)10 according to the norm NF S 90-351 : 2003.
- The microbiological class according to the norm NF S 90-351 : 2003 is :

B5	B10
Methicilin resistant	Aspergillus niger
Staphylococcus aureus (MRSA)	
Candida albicans	

- The painted face doesn't allow the growth of : S.aureus (CIP 103.514) and C.albicans (UMIP 1180.79).

GENERAL CONCLUSIONS OF TILES MEDICARE STANDARD

Classification of tiles

The tiles MEDICARE STANDARD can be used in room of area 4 according to the norm NFS 90-351 : 2003.

Tests	Norms	Acceptance criteria	Real values	Conformity
Particular class normal conditions face	ISO 14644-1	ISO class 5	ISO class 5	Conform
Particular class normal conditions back	ISO 14644-1	ISO class 5	ISO class 5	Conform
Recovery time	NF S 90-351	CP _(0,5) 10	2.3 minutes	Conform
Microbiology air test	<i>Methicilin resistant Staphylococcus aureus (MRSA)</i>	B10	B5	Conform
	<i>Aspergillus niger</i>	B10	B10	Conform
	<i>Candida albicans</i>	B10	B5	Conform

Remarks

- This controls shows that the tiles MEDICARE STANDARD could be used in area 4 according to the norm NF S 90-351 : 2003.
- The microbiological tests as been made under Microbiological Safety Cabinet
- The completed results are in the report :

n° 10 12 160 – ROCKFON Medicare Standard / 1 Ver.0 written the 20th march 2011 and 11 09 087 ROCKFON Medicare Air/1 Ver.0 written the 28th September 2011

The Director

