



GENERAL NOTES

1. BRACE CEILING TRANSITIONS AS REQUIRED BY ENGINEER OF RECORD TO MEET LOCAL CODES - SPECIAL CONSIDERATIONS MAY BE REQUIRED IN SEISMIC AREAS.
2. HANGER WIRE TO BE SPACED MAX. AT 48" O.C. MAX. ADDITIONAL HANGER WIRE MAY BE REQUIRED DEPENDING ON LOAD IMPOSED ON THE CEILING SUSPENSION.
3. CANTILEVERED CONDITIONS SHALL BE CALCULATED BY ENGINEER OF RECORD.
4. FIELD VERIFY ALL CONDITIONS AND DIMENSIONS.
5. STRUCTURE CAN VARY FOR CROSS TEE BEING USED, WIRE SPACING TO BE DETERMINED BY ENGINEER OF RECORD TO SUPPORT IMPOSED LOADS.

THIS DOCUMENT IS THE PROPERTY OF ROCKFON. ANY UNAUTHORIZED COPYING, REPRODUCING OR FACSIMILIES WITHOUT THE EXPRESS WRITTEN CONSENT OF ROCKFON IS STRICTLY PROHIBITED.



4849 S. Austin Ave. Main Phone: (708) 563-4600
 Chicago, IL 60638 Toll Free: (800) 323-7164
 www.rockfon.com Fax: (800) 222-3744
 mailinfo.na@rockfon.com

STANDARD SUSPENDED DRYWALL SOFFIT DETAIL

DATE: 03/20/24

REV.: -

SCALE: 3" = 1'-0"

DWG. BY:

REV. DATE:

DWG. NO.: